## DEPARTMENT OF HOUSING AND COMMUNITY DEVELOPMENT DIVISION OF CODES AND STANDARDS

1800 Third Street, Room, 260, P.O. Box 1407 Sacramento, CA 95812-1407 From TDD Phones 1 (800) 735-2929 (916) 445-9471 FAX (916) 327-4712 www.hcd.ca.gov



May 20, 2002

## **INFORMATION BULLETIN 2002-09 (SHL)**

TO: City and County Building Officials

State Housing Law Interested Parties Factory-built Housing Manufacturers Factory-built Housing Third-Parties Factory-built Housing Interested Parties

**Division Staff** 

SUBJECT: FIRE SAFETY RISK POSED BY RECALLED FURNACES

This Information Bulletin transmits important information provided to the Department of Housing and Community Development (the Department) by the Office of the State Fire Marshal (OSFM) regarding recalled furnaces.

Certain attic-mounted furnaces sold in California between 1983 and 1994 under various brand names pose a substantial risk of fire. These furnaces are the focus of a recall initiated by the U.S. Consumer Product Safety Commission.

Please carefully review the Informational Bulletin issued by the Office of the State Fire Marshal included on the reverse, as it contains more specific information about the recalled furnaces and the contact information for interested parties. Please direct your questions regarding this matter to the contacts listed in the Informational Bulletin issued by the OSFM.

Norman Sorensen Deputy Director

Attachment

Issued: 01-02-02 State Fire Marshal's web site: <a href="http://osfm.fire.ca.gov">http://osfm.fire.ca.gov</a>



California State Fire Marshal Informational Bulletin

## Furnaces Recalled Pose Significant Fire Safety Risk

On July 9, 2001, the US Consumer Product Safety Commission (CPSC) announced a recall of about 30,000 furnaces sold in California (Recall #01-189). *These furnaces pose a substantial risk of fire*. The units involved are gas-fired horizontal furnaces equipped with steel NOx rods installed above the burners (commonly called "NOx rod furnaces"). Several Southern California fire agencies have reported residential fires involving these furnaces. CPSC has received 50 reports of fires associated with 140,000 horizontal furnaces manufactured by Consolidated Industries. So far, no injuries have been reported.

Consolidated Industries (formerly Premier Furnace Co.), which is currently involved in Chapter 7 bankruptcy proceedings, manufactured approximately 140,000 of these furnaces for sale in California between 1983 and 1994 under many different brand names. Seven firms, which sold the Consolidated Industries units under their own labels, are offering to repair or replace certain units. The trade names of these furnaces are Amana, Bard, Sunburst (Carrier), American Best Goettl, Franklin Electric, Goodman, GMC, Hamilton Electric, Janitrol, Johnstone, Liberty, Comfort-Aire, Trane and American Standard. These furnaces originally sold for about \$2,000 each. For a list of specific brand names and model numbers, please refer to CPSC's web page at <a href="https://www.cpsc.gov/cpscpub/prerel/prhtml01/01189.html">www.cpsc.gov/cpscpub/prerel/prhtml01/01189.html</a>

About 110,000 of these furnaces were manufactured and distributed under the Premier or Consolidated labels and are not covered by this recall program. However, on- going private litigation could enable consumers to recover at least some of their out-of-pocket expenses for the Premier/Consolidated brand of furnaces. For more information on this private litigation, call (408) 808-1410 or visit their web site at <a href="https://www.white-acdonald.com">www.white-acdonald.com</a>

Additional consumer information regarding the recall is available by telephone toll-free at (877) 347-6456 or at www.furnaceinspect.com